

TENTS, CANOPIES, AND OTHER MEMBRANE STRUCTURES **PERMIT REQUIREMENTS**

1. A detailed site and floor plan must be submitted and approved by the Reno Fire Department.
2. All tents and canopies shall be constructed of non-flammable material and must have attached the approval seal from The California State Fire Marshal's Office or an equivalent testing facility.
3. Tents and canopies shall be erected according to manufacturer's recommendations in an area that is free of all combustible material and vegetation. A 30 foot clearance around the tent is required.
4. Tents shall not be located within 20 feet of buildings, vehicles, and/or property lines.
5. All tents shall have a minimum of two exits unless at the time of plan submittal it is determined that the tent size requires more. Exit signs shall have a source of illumination available.
6. A minimum of two fire extinguishers with a rating of 2A10BC are required. The extinguishers must have current tags with the State of Nevada seal. Additional fire extinguishers may be required after floor plan submission.
7. In public areas, the aisle width shall be no less than 44". In employee only areas, the width may be reduced to 24".
8. No smoking will be permitted inside tents. "No Smoking" signs shall be clearly displayed.
9. Open flame or similar devices used for cooking, exhibition, etc. are not permitted inside the tent. When approved for use outside the tent, they shall be located no less than 20 feet from the tent.

Additional requirements are subject to review and inspection of the event. For further information regarding tents, canopies, and other membrane structures, please reference Chapter 24 of the International Fire Code.